जा.क्र.सा.बां.उपवि/पलूस/ ४९ ७/२०२५ उपविभागीय अधिकारी (स्थापत्य) सा.बां.उपविभाग,पलूस यांचे कार्यालय ता.पलूस जि.सांगली दिनांक :92/०६/२०२५

## **BUILDING STABILITY CERTIFICATE**

This is to Certified that the exisiting building Vikas Charitable Trust's, "Kirloskar High School & Junior College at Kirloskarwadi" CTS No 437,438 at Kundal & Gat No 903 at Sawantpur Tal.Palus Dist.Sangli have 8 building blocks occupied by "Kirloskar High School & Junior College at Kirloskarwadi" have complied with the Building safety requirements in accordance with National Building code Rules 2005 & 2016 & verified by the officers concerned of Maharashtra Public Works Department on Date.10/06/2025 in the presence of Mr..M.S.Patil Sub Divisional Officer(Civil) P.W.Sub Division,Palus & Mr..D.V.Mane Assistant Engineer GrII P.W.Sub Division,Palus also Mr..U.B.Kulkarni, Principal & that the building is fit for occupancy upto classes V to X with effect from Date.11/06/2025 for a period of **One Year** in accordance with rule & subject to compliance of the specific conditions as appended.

This stability certificate is issued on request letter of Trustee, Vide Letter Dtd 16/05/2025 Vikas Charitable Trust's, A/P-Kirloskarwadi Tal. Palus Dist. Sangli for CBSE Board ffilation Purpose with reference to Drawings attached & cerified by Kanitkar & Kulkarni (Structural Consultants & Chartered Engineers) Kothurd Pune Vide Letter Dtd. 03/06/2025

- 1. Building 1:- (G + 1 load Bering Structure)
- Toilet door & dado Tiles should be replaced.
- Dampness in staircase should be cured.
- 2. Building 2:- (Ground Floor load Bering Structure)
- \* Replace Damage Eaves Board.
- 3. Building 3:- (Ground Floor load Bering Structure)
- 4. Building 4:- (Work Shop)
- \* Replace Damagae AC Sheets.
- 5. Building 5 :- (Play Group)
- Replace Damage Door.
- 6. Building 6,7 & 8

Vikas Charitable Tins

KIRLOSKARWAR

416 30×

School & Junior Colle

Principal

Kirloskar High School & Jr. College, Kirloskarvadi. 416308

Sub Divisional Officer (Civil) P.W.Sub Division,Palus